

Certificate of Compliance

We hereby declare that the technical file of product complied with the requirement of directive (2014/34/EU) ATEX Directive.

Certificate No.: UQ-10655


Manufacturer

Name : POK SAS

Address : 18 COURS ANTOINE LAVOISIER, 10400 NOGENT-SUR-SEINE, FRANCE

Products : POK REMOTE CONTROL FIRE MONITOR

Testing Method: EN 60079-0:2012, EN 60079-15:2010

 II 2 G Ex nR IIC T6 Gc
-40 C < +60 C

The Certification body has performed an audit of the above product quality system covering the design, manufacture and final inspection of the certified product. The quality system has been assessed, approved and is subject to continuous surveillance according to Directive (2014/34/EU) ATEX.

This certificate is issued under the following conditions:

1. It applies only to the quality system maintained in the manufacture of above referenced models and it does not substitute the design or type-examination procedures, if requested.
2. The certificate remains valid until the manufacturing conditions or the quality systems are changed.
3. The certificate validity is conditioned by positive results or surveillance audits.

Validity of this certificate can be verified at www.ukcertifications.co.uk/verify

Date of Certification	18 th July 2018
1 st Surveillance Audit Due	17 th July 2019
2 nd Surveillance Audit Due	17 th July 2020
Certificate Expiry (subject to the company maintaining its system to the required standard)	17 th July 2021



Authorised Signatory

